



Technical Evaluation of UPS and Batteries

The tendering process held on 09/11/2017 for purchasing UPS and Batteries. 05 (five) firms participated in tendering procedure.

1. **PPRA Reference No:** 82496T23102017985
2. **Date and Time of Bid Closing:** 09/11/2017 @ 11:00 A.M.
3. **Date and Time of Bid Opening:** 09/11/2017 @ 11:30 A.M.
4. **No. of Bids Received:** 05 (five)
5. **Item:** UPS and Batteries


The names of the firms are given below:

- i. Dream World Traders and Event Organizer
- ii. Bilal Traders & Stationers
- iii. Arslan Traders
- iv. Arshad Amjad & Abid Private Ltd.
- v. Smart Vision Documents System

Dream World Traders and Event Organizer technically disqualified by the Purchase Committee during its meeting due to non-attachment of specifications on the letter head.

Name of Bidder	Required Items	Qty.	Technically Qualified	Technically Disqualified	Reason
Bilal Traders & Stationers Homage2000 W, 24 V	UPS 2000 Watts 24 V	10	--	Technically Disqualified	<ul style="list-style-type: none">• Model No. is not mentioned. Warranty is not given. Copy of CNIC is not attached.• All pages of bid document was not signed and stamped by the bidder as per our Terms and Condition No. 1.
Arslan Traders Homage 2000 W Made by China			--	Technically Disqualified	<ul style="list-style-type: none">• Model No. is not mentioned. Warranty is not given.• All pages of bid document was not signed and stamped by the bidder as per our Terms and Condition No. 1.
Arshad Amjad & Abid Private Ltd Homage Ups Model No HTD-2211SCC 2200VA/24 V DC			--	Technically Disqualified	<ul style="list-style-type: none">• The given specifications do not match our requirements. Warranty is not given. 2200VA=1600W

Name of Bidder	Required Items	Qty.	Technically Qualified	Technically Disqualified	Reason
Smart Vision Documents System UPS Brit Sine-Line Interactive UPS Brit Sine BSI-20 L. <ul style="list-style-type: none"> Capacity 2000VA True sine wave with very low harmonic distortion, best for all kinds of appliances With AVR function, range 140 VAC~275 VAC With charger function, 15A With toroidal transformer (C.R.G.O Transformer) technology, more energy – saving Output 220V, 50/60 Hz Input DC 24V LED Graphic human-Machine interface Very low unloading current Very low audible noise Very low electromagnetic interference Intelligent 3 stage charger protects your battery well Integrated frequency automatic tracking technology , generator compatible Overload protection Short circuit protection Full protection against battery UV/OV 3 stage charging for optimized battery performance Micro controller based intelligence system Output power factor 0.6 			--	Technically Disqualified	<ul style="list-style-type: none"> The given specifications do not match our requirements. Warranty is not given. 2000VA=1500W All pages of bid document was not signed and stamped by the bidder as per our Terms and Condition No. 1.
Bilal Traders and Stationers 200 V AGS 220 V Exide 225 V Volta 225 V Osaka		20	--	Technically Disqualified	<ul style="list-style-type: none"> Conditional bid under the condition No. 5 is liable to be rejected. All pages of bid document was not signed and stamped by the bidder as per our Terms and Condition No. 1.
Arslan Traders Osaka P-225s/220 AMP Liquid Battery. Made by Pak.	Battery 220 VA Heavy Duty		--	Technically Disqualified	<ul style="list-style-type: none"> The given specifications do not match our requirements. All pages of bid document was not signed and stamped by the bidder as per our Terms and Condition No. 1.
Arshad Amjad & Abid Pvt. Ltd Exide Batteries Model No. N220 25 Plates			--	Technically Disqualified	<ul style="list-style-type: none"> The given specifications do not match our requirements.
Smart Vision Documents System Not Applied			--	--	--


Chairperson Purchase Committee